

EC Declaration of conformity

CERTIFICATE NO.: NET01CE14

Applicant:	Jets Vacuum AS
Producer:	Partner Plast AS Standgata 3 6300 Åndalsnes NORWAY
Product:	Small wastewater treatment systems for up to 50 PT – Prefabricated septic tanks.
Identification:	Drawing 172382-002 Rev00, Volume 3000 L
Dimensions:	2210*2210*1420 (l*w*h in millimetre)
Test laboratory:	Nordisk Emballasje Testing AS
Test standards:	NS-EN 12566-1:2000+A1:2005

The certificate of conformity is based on an evaluation of three samples of the above mentioned product. Technical report and documentation are at the applicant`s disposal. This is to certify that the tested samples are in conformity with The Decision of the commission 95/467/EC. The CE marking symbol shall be in accordance with Directive 93/68/EEC, in its latest amended version. The certificate does not imply assessment of the production and does not permit the use of NET`s logo. The applicant of the certificate is authorized to use this certificate in connection with EC declaration of conformity.

Test report:	NET51CE05A
Appendix:	Page 2 in this document



Porsgrunn 12.06.2014

Nordisk Emballasje Testing AS
Certification

Certified by:



Rune Madsen Fink
Managing Director



The CE marking may only be used if the samples are produced as when tested in test report NET51CE05A, and as long as they are a part of an annual production control program.

APPENDIX TO CERTIFICATE

Marking of the tank shall be durable, accessible and clearly readable after installation.
The marking should preferably be on the inside of the shaft, or when it is not possible, on the tanks outer wall of the inlet area.

The tank shall be marked legibly, visibly and durably by following information:
EN 12566-1
Product name and nominal size
Information on the relevant essential characteristics: water tightness, crushing test
Material type; PE
Name or identifying mark of the manufacturer
Date of manufacture
The CE marking symbol
Last two digits of the year of CE marking