

Product certificate

CERTIFICATE NO: NET51EN01

Applicant: PartnerPlast AS

Producer: PartnerPlast AS
Strandgata 3
N-6300 Åndalsnes
NORWAY

Product: Plastics piping systems for non-pressure underground drainage and sewerage – Polyethylene (PE) – Part 2: Specifications for manholes and inspection chambers in traffic areas and deep underground installations



Identification: Drawing 11672 and 11677

Description: Rotational moulded in two parts; the top (blue, double wall) and the inspection chamber (natural, single wall)

Test laboratory: NET Test Center, Norway

Test standards: The product meets the requirements in NS-EN 13598-2:2009

The product certificate is based on an evaluation of three samples of the above-mentioned product. Technical report and documentation are at the applicant's disposal. The certificate imply a yearly assessment of the production and permit the use of NET's logo only as long as the manufacturer is a part of an inspection program that is monitored by NET.

Test report: NET569IC01

Marking:



"NET-Lighthouse" is a quality marking symbol and means that the product is type-tested and meets regulatory requirements and that the manufacturer is a part of an inspection program that is monitored by NET. The Lighthouse marking may only be used as long as the samples are produced as when tested in test report NET569IC01.

51EN01
NET17025.COM

EN 13598-2 Required durable in use.
PE
H = 4 m



Certified by:



Rune Madsen Fink
Managing Director

Porsgrunn 01.06.2018

Nordisk Emballasje Testing AS
Certification